

WMFL Testing

Level III – 30 Minute Physical Attack

1. 2 lb. claw hammer, claw end; 5 minutes
2. Cold chisel/screwdriver; 5 minutes
3. 10 lb. sledge hammer; 5 minutes
4. Fire extinguisher dry chemical type for an NBC fire class with 4A-60DC UL rating; 5 minutes
5. Propane burner of temp. approximately 2,200 degrees F with tip of burner 4" from glass surface, and with nozzle diameter as required to result in heat source approximately 1" in diameter; 5 minutes.
6. 4 lb. hammer, 5 minutes

Level II – 60 Minute Physical Attack

1. 2 lb. claw hammer, claw end; 5 minutes
2. Cold chisel/screwdriver; 5 minutes
3. 10 lb. sledge hammer; 5 minutes
4. ASTM A500 grade B 1-1/2" diameter pipe 3 feet long along with ASTM 36 2" angle iron 3 feet long; 5 minutes
5. ASTM A615 grade 60 deformed #8 rebar for concrete reinforcement, 3 feet long; 5 minutes
6. 4" x 4" table leg/chair leg (oak) 3 feet long; 5 minutes
7. Fire extinguisher dry chemical type for ABC fire class with 4A-60BC U/L rating; 5 minutes
8. 10 lb. sledge hammer; 5 minutes
9. Heated clothes hanger along with heated knife 10" blade from 1/4" thick cold chisel steel); 5 minutes
10. Propane burner of temperature approximately 2,200 degrees F with tip of burner 4" from glass surface, and with nozzle diameter as required to result in heat source approximately 1" in diameter; 5 minutes
11. 4 lb. hammer; 5 minutes
12. ASTM A500 grade B 3" diameter pipe 3 feet long or 1" x 1" angle iron 3 feet long; 5 minutes

Level I – 60 Minute Physical Attack Plus .44 Magnum

1. Same test as 60 minute above, plus 24 rounds from a .44 magnum at 30 yards.